



# DC Prep PCS (Edgewood Middle) - Lead in Water Test Results



## FY20 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
DC Prep PCS [Edgewood - Middle School]	WS-059-001	Cooler	1	In hallway across from room 108	High	Left	WF-082019-059001-02	10/25/2019	FT-FY20-082019-059001-A	<1	FT-FY20-082019-059001-B	<1
DC Prep PCS [Edgewood - Middle School]	WS-059-002	Cooler	1	In hallway across from room 108	Low	Right	WF-082019-059002-02	10/25/2019	FT-FY20-082019-059002-A	<1	FT-FY20-082019-059002-B	<1
DC Prep PCS [Edgewood - Middle School]	WS-059-003	Cooler	1	In hallway across from room 105	High	Left	WF-082019-059003-02	10/25/2019	FT-FY20-082019-059003-A	<1	FT-FY20-082019-059003-B	<1
DC Prep PCS [Edgewood - Middle School]	WS-059-004	Cooler	1	In hallway across from room 105	Low	Right	WF-082019-059004-02	10/25/2019	FT-FY20-082019-059004-A	<1	FT-FY20-082019-059004-B	<1
DC Prep PCS [Edgewood - Middle School]	WS-059-005	Cooler	1	In hallway across from room 105 on right side	High	Left	WF-082019-059005-02	10/25/2019	FT-FY20-082019-059005-A	<1	FT-FY20-082019-059005-B	<1
DC Prep PCS [Edgewood - Middle School]	WS-059-006	Cooler	1	In hallway across from room 105 on right side	Low	Right	WF-082019-059006-02	10/25/2019	FT-FY20-082019-059006-A	<1	FT-FY20-082019-059006-B	<1
DC Prep PCS [Edgewood - Middle School]	WS-059-007	Health Suite	1	In health suite 121			WF-082019-059007-02	10/25/2019	FT-FY20-082019-059007-A	1.4	FT-FY20-082019-059007-B	<1
DC Prep PCS [Edgewood - Middle School]	WS-059-008	Food Prep Sink	2	In kitchen 238			WF-082019-059008-02	10/25/2019	FT-FY20-082019-059008-A	<1	FT-FY20-082019-059008-B	<1
DC Prep PCS [Edgewood - Middle School]	WS-059-009	Cooler	2	In hallway across from room 213	High	Left	WF-082019-059009-02	10/25/2019	FT-FY20-082019-059009-A	<1	FT-FY20-082019-059009-B	<1
DC Prep PCS [Edgewood - Middle School]	WS-059-010	Cooler	2	In hallway across from room 213	Low	Right	WF-082019-059010-02	10/25/2019	FT-FY20-082019-059010-A	<1	FT-FY20-082019-059010-B	<1
DC Prep PCS [Edgewood - Middle School]	WS-059-011	Cooler	2	In hallway across from room 212	High	Left	WF-082019-059011-02	10/25/2019	FT-FY20-082019-059011-A	<1	FT-FY20-082019-059011-B	<1
DC Prep PCS [Edgewood - Middle School]	WS-059-012	Cooler	2	In hallway across from room 212	Low	Right	WF-082019-059012-02	10/25/2019	FT-FY20-082019-059012-A	<1	FT-FY20-082019-059012-B	<1